

MOTOR CIRCUIT ANALYSIS TESTING AT WATERSURE USING ALLTEST PRO 5 ANALYSER.

- TO UNDERSTAND TRUE CONDITION OF PLANT CRITICAL MOTORS.
- TO REPLACE/OVERHAUL MOTORS BEFORE CATASTROPHIC FAILURE OCCURS.
- TO HELP ENSURE MOTOR AND PLANT RELIABILITY INTO THE FUTURE AT WATERSURE.

COMMON CAUSES OF ELECTRIC MOTOR FAILURE

- Low insulation resistance
- Overheating
- Contamination
- Moisture ingress
- High vibration
- Rotor failure
- Over current
- Bearing failure

POSSIBLE CAUSES OF MOTOR FAILURE INTO THE FUTURE AT WATERSURE:

- Motor winding deterioration due to salt air contamination (causing breakdown of winding insulation and eventually causing turn to turn, coil to coil and phase to phase short circuit)
- Loose connections causing overheating of cables.
- Corroded connections due to moisture from water ingress or condensation.
- Collapsed bearing due to lack of lubrication, incorrect installation or high load. This can cause rotor to rub on stator and destroy windings.
- Polyamide cage in cylindrical roller bearings (ABB motors built in India are likely to have polyamide or plastic cages in their roller bearings). Belt driven loads such as centrifuge primary motor and Backwash air blowers are prone to bearing failure if inadequate lubrication (due to high radial load and possibility of polyamide cage especially in 2 pole motors).
- NDE bearing spinning in housing causing looseness. Eventually rotor will rub on stator and short circuit stator (more likely in small motors with aluminum frame).
- Stator eccentricity from soft foot. This causes windings to vibrate at 2 x line frequency and is very bad for winding insulation. The vibration is at 2 X line Hz due to maximum magnetic field strength occurs 2 x per cycle.
- Motor running above full load current of motor on nameplate causing overheating
- Cracked rotor bars/shorting ring could be a failure mode into the future. This is caused by high amount of stop starts overheating rotor bars and eventually causing rotor bars to crack (will only happen if motors are DOL starting and have many stop/start cycles).


MOTOR CIRCUIT ANALYSIS TESTS CAN HIGHLIGHT:

- Turn to turn short inside coil
- Short circuit between coils on same phase
- Short circuit between phases
- Short circuit to earth
- Loose or corroded connections in motor or MCC panel
- Contaminated or overheated windings
- Incorrectly configured terminal strip (if testing at motor)
- Rotor condition/cracked shorting ring or rotor bars (dynamic tests for rotor condition)

MCC TESTS CARRIED OUT AT KONIAMBO POWER

STATION:


Motor circuit analysis, testing and findings	Number of motors tested
Burnt insulation	3
Terminal corrosion	23
Moisture ingress	7
Anti condensation heater failure	3
Loose motor terminal connections	50
loose connections in MCC	4
Incorrectly wired (star instead of delta)	6
Incorrectly configured on terminal bock	69
Winding short circuit/open circuit	3
Low insulation to earth	3
Motor good condition and no issues	160




COMPARING MOTOR DIAGNOSTIC TECHNOLOGIES:

Motor diagnostic technology comparison									
	Stator faults	Rotor faults	Connection faults	Air gap faults	Insulation	Bearing	Vibration	Align	Temp
Off line testing									
High potential testing					High				
Insulation resistance tests					High				
Ohm meter testing	Low	Low	Low						
Polarization index testing					High				
Motor maintenance	Low		High		High				
MCA testing	High	High	High	High	High				
Online testing									
Vibration analysis	Low	High		High		High	High	High	
Infra-red inspection	High	Low	High			High			High
Ultrasonic testing	Low					High			
Motor current analysis	Low	High		High		Low	Low	Low	
MCA, infra-red, vibration and ultrasonics	High	High	High	High	High	High	High	High	High


TURN TO TURN WINDING SHORT




COIL TO COIL WINDING SHORT:




PHASE TO PHASE WINDING SHORT:




WINDING SHORTED IN
STATOR SLOT:




PHASE DAMAGE DUE TO UNBALANCED VOLTAGE:




SHORT AT EDGE OF STATOR SLOT:



WINDING DAMAGED DUE TO OVERLOAD:



DAMAGED CAUSED BY LOCK ROTOR:



ALLTEST PRO 5 MOTOR ANALYSER



ALL-TEST PRO 5 TESTS THAT CAN BE CARRIED OUT

- Resistance
- Impedance
- Inductance
- Contamination (DF)
- Phase angle
- Current/frequency (I/F)
- Test value static (TVS)
- Dynamic test
- Insulation resistance


ALL TESTS PRO 5 TESTS AND TOLERANCES

Test Result	Tolerance	Detail
Resistance (R)	<5%	Likely loose or faulty connections
Impedance (Z) and Inductance (L)	<5%	If random wound <1000V, unbalance might be due to rotor position or motor design. If form wound then a fault may have occurred.
Dissipation Factor (DF)	>6%	Likely winding contamination or overheated windings
Phase Angle (Fi)	+/- 2 digits (degree) from average	Indicates a winding short: 74, 75, 76 OK; 74, 74, 76 suspect; 73, 73, 76 failed
I/F	+/- 2 digits (%) from average	Indicates a winding short: -44, -45, -46 OK; -44, -46, -46 suspect; -42, -45, -45 failed
TVS	>3%	Likely change in condition of the winding or rotor
Dynamic Test	Stator: >1.5%	Likely stator winding issue
	Rotor: >15%	Likely rotor issue
Insulation Resistance	See INS Guide	Indicates poor insulation to ground (I.e. ground fault)

MCA RESISTANCE TEST(MEASURED IN OHMS):

- It is the simple DC resistance of the circuit. If imbalance is found, it could mean loose connection at back of MCC, motor j/box or soldered coil connections inside motor.
- This test is very important due to the formula power (or heat) in watts = current squared x resistance. If you had a 0.1 ohm resistance across a connection in a circuit drawing 100 amps, your heat generated would be $100 \times 100 \times 0.1 = 1000$ watts. That is why we have burnt cables get burnt and fires occur in mcc's.
- Values can be effected by induced voltages from live cables nearby. Need to check at motor to confirm.

Resistance imbalance on a water pump using all-test pro 4




Loose connection causing overheated supply lead to motor



MCA results after repairs carried out. Resistance now balanced.


	1	2	3	
Resistance	0.816	0.816	0.817	0.074
Impedance	95.0	93.0	93.0	1.42
Inductance	19.0	18.0	18.0	3.64
Phase Angle	78	79	79	1.00
I/F	46	46	47	1.00
Insulation	<input type="text"/>			MegOhm



Findings

- No insulation resistance tested.
Good winding.


Resistance imbalance on a cooling fan using all-test pro 4



Corroded connections causing increased resistance.



MCA results after repairs carried out. Resistance now balanced



Resistance imbalance on test motor using All

test pro 5

Individual Analysis - 3 phase

Company: Watersure Location: Test motor
EquipmentID: Test position 2 Name: position 2 Type: 3PhaseAC

20190515-19:30:20 [B]

		32	21	13	
Resistance (Ω)	BAD	17.6	19.5	19.5	6.61
Impedance (Ω)		208	240	229	7.68
Inductance (mH)		330	381	362	7.68
Phase Angle ($^{\circ}$)	OK	71.8	71.2	70.5	0.683
I / F (%)	OK	-42.2	-41.8	-41.8	0.283
Stator					
Rotor					
Insulation (M Ω)	OK	407	M Ω	TVS	677
Contamination(%)	OK	3.80%		Ref Value	
Capacitance (nF)		38.9	nF		
Frequency (Hz)		100		Reference	
Direct Test At Motor <input type="checkbox"/>					

Manual Values

Findings
Check for loose connections.
Recommend check at motor if tested from MCC.
Insulation Test Voltage: 500V

NOTE

32 21 13

SAVE NOTE
TREND
Rotor

0% Sdev 0% 0% Sdev 0% 0% Sdev 0%

Watersure Sea water lift pump motor resistance

Individual Analysis - 3Phase
— □ ×

Company	Watersure	Location	Sea water pumps		
EquipmentID	1041043	Name	Sea water lift	Type	3PhaseAC

20190417-23:24:00 [B]

20190417-23:26:28

20190417-23:41:43

		32	21	13	
Resistance (Ω)	WARN	0.0550	0.0514	0.0545	4.19
Impedance (Ω)		7.35	8.44	8.37	8.71
Inductance (mH)		2.92	3.36	3.33	8.71
Phase Angle (°)	OK	83.0	81.7	81.9	0.780
I / F (%)	OK	-45.9	-44.9	-45.0	0.646
Stator					
Rotor					
Insulation (MΩ)	OK	>999	MΩ	TVS	6.90
Contamination(%)	OK	1.86%		Ref Value	
Capacitance (nF)		128	nF		
Frequency (Hz)		400		Reference	
Direct Test At Motor <input type="checkbox"/>					

Manual Values

Findings

Check for loose connections.

Recommend check at motor if tested from MCC.
Insulation Test Voltage: 1,000V

NOTE

X

0% Sdev 0%

X

0% Sdev 0%

X

0% Sdev 0%

SAVE NOTE
TREND
Rotor

↓
↑
✘


Watersure sea water lift pump motor corroded lugs



MCA IMPEDANCE TEST (MEASURED IN OHMS):

- Impedance is the total AC and DC resistance in the winding.
- Any imbalances in inductance normally indicate position of rotor (if impedance and inductance follow the same pattern match) and is not cause for concern.
- If the impedance imbalance does not match the inductance, it can indicate overheated or contaminated windings. Recommend checking at motor J/box. Normally can smell overheated windings inside j/box.
- If the impedance result reads zero, then that is a good indication of a shorted winding

Indication of contaminated or overheated windings using All-test pro 4



INDUCTANCE (MEASURE IN HENRIES)

- Inductance measurement is the indicator of the magnetic strength of windings.
- If the inductance imbalance is high, but impedance values are normal, it can indicate shorted winding.
- Will show big imbalance if windings are shorted.
- If pattern match is the same as impedance, then it is the position of the rotor causing this and is not a problem.

Impedance and inductance above warning values of 5%.

Individual Analysis - 3Phase

Company: Watersure Location: Backwash pump
EquipmentID: 929G1MO001A Name: G1 DMPF BW Pmp A Type: 3PhaseAC

	32	21	13	
Resistance (Ω)	0.0218	0.0215	0.0217	0.642
Impedance (Ω)	5.78	5.65	7.14	15.4
Inductance (mH)	2.30	2.25	2.84	15.4
Phase Angle ($^\circ$)	82.6	82.6	81.5	0.762
I / F (%)	-44.5	-44.8	-44.1	0.396

Stator
Rotor

Insulation (M Ω) M Ω TVS
Contamination(%) OK Ref Value
Capacitance (nF) nF
Frequency (Hz) Reference

Direct Test At Motor Manual Values

Findings
Recommend check at motor if tested from MCC.
Insulation Test Voltage: 500V

NOTE
Tests indicate good winding condition.

SAVE NOTE
TREND
Rotor

32 21 13

0% Sdev 0% 0% Sdev 0% 0% Sdev 0%

Impedance and inductance pattern match and same values indicates there is no fault and it is the position of the rotor that is causing this imbalance.

ult

PHASE ANGLE (MEASURED IN DEGREES):

- Phase angle is the relationship between the AC current to the applied voltage from MCA unit.
- The results are expressed in degrees angular (0 to 90) and is the difference between the current and the voltage.
- In an inductive circuit (as per induction motor) voltage leads current by 90 degrees in the sinewave.
- If the voltage leads the current the phase angle is positive.
- If the voltage lags the current, then the phase angle is negative.
- Imbalance in phase angle of more than 2 or 3 digits, can indicate coil to coil short.

Stream 2 CIP pump A phase angle

Individual Analysis - 3Phase

Company: Watersure Location: RO cleaning feed
 EquipmentID: 189G2MO003A Name: G2 CIP Pmp A Type: 3PhaseAC


	32	21	13	
Resistance (Ω)	OK 0.00679	0.00686	0.00674	0.895
Impedance (Ω)	4.62	5.15	5.83	12.1
Inductance (mH)	1.84	2.05	2.32	12.1
Phase Angle ($^{\circ}$)	BAD 80.6	77.4	76.2	2.49
I / F (%)	WARN -43.6	-41.5	-40.4	1.74
Stator				
Rotor				
Insulation (M Ω)	OK 640	M Ω	TVS 4.50	
Contamination(%)	BAD 16.2%		Ref Value	
Capacitance (nF)	58.5	nF		
Frequency (Hz)	400	Reference		
Direct Test At Motor	<input type="checkbox"/>			

Manual Values

Shorted Stator Winding. Repeat the test to confirm.
 Contaminated or Overheated
 Recommend performing rotor compensated winding test.
 See manual for details.
 Recommend check at motor if tested from MCC.
 Insulation Test Voltage: 1,000V


NOTE
 Carried out same test 3 X with exactly the same result. Cannot carry out rotor compensated test with alltest pro5 (need alltest pro33 to do this) Carried out dynamic test which also revealed stator and possible rotor issues.
 Have carried out further dynamic tests on stream 1 A (good motor) which indicate

32




0% Sdev 0%

21



0% Sdev 0%

13








0% Sdev 0%

SAVE NOTE

TREND

Rotor

I/F (CURRENT/FREQUENCY) MEASURED IN PERCENTAGE:

- Low voltage AC signal is injected into windings at a specific frequency and current is measured. The Hz is then doubled and current is measured.
- The I/F reading is ratio of the current at doubled frequency, compared to original frequency.
- An imbalance of more than 2 digits indicates possibility of phase to phase short. If the motor trips on startup then it is usually a phase to phase short or short to earth fault.
- A motor can have a good insulation resistance to earth (as per typical electricians test with megger), but still trip due to internal phase to phase fault.
- Phase to phase fault have potential to draw large currents and should trip motor out on overcurrent.

Test motor I/F (and phase angle) imbalance

Individual Analysis - 3Phase

Company: Location:

EquipmentID: Name: Type:

		32	21	13	
Resistance (Ω)	OK	<input type="text" value="17.6"/>	<input type="text" value="17.7"/>	<input type="text" value="17.7"/>	<input type="text" value="0.237"/>
Impedance (Ω)		<input type="text" value="218"/>	<input type="text" value="290"/>	<input type="text" value="244"/>	<input type="text" value="15.7"/>
Inductance (mH)		<input type="text" value="346"/>	<input type="text" value="461"/>	<input type="text" value="387"/>	<input type="text" value="15.8"/>
Phase Angle (°)	BAD	<input type="text" value="69.6"/>	<input type="text" value="62.0"/>	<input type="text" value="67.7"/>	<input type="text" value="4.46"/>
I / F (%)	BAD	<input type="text" value="-42.4"/>	<input type="text" value="-47.5"/>	<input type="text" value="-42.0"/>	<input type="text" value="3.53"/>
Stator					
Rotor					
Insulation (MΩ)	OK	<input type="text" value="364"/>	MΩ	TVS	<input type="text" value="752"/>
Contamination(%)	OK	<input type="text" value="3.54%"/>		Ref Value	<input type="text"/>
Capacitance (nF)		<input type="text" value="19.9"/>	nF		<input type="text"/>
Frequency (Hz)		<input type="text" value="100"/>		Reference	<input type="text"/>

Direct Test At Motor

32 21 13

0% Sdev 0%

0% Sdev 0%

0% Sdev 0%

Findings

Shorted Stator Winding. Repeat the test to confirm. Recommend performing rotor compensated winding test. See manual for details. Recommend check at motor if tested from MCC. Insulation Test Voltage: 500V

NOTE

INSULATION RESISTANCE TEST TO EARTH (MEASURED IN MEGOHMS).

- Measurement should be greater than 99 meg ohm.
- If reading below 30 Meg, indication of moisture ingress.
- If readings are below 1 meg ohm, may need to replace motor. Will need to carry out investigation at motor to check for moisture ingress and winding condition).
- If readings are close to zero, then indicates short to frame of motor (could be short across terminals in motor j/box so recommend checking at j/box).
- If earth loop impedance is too high (resistance of earth cable back to MCC), then a motor can become live if short to frame and high earth cable resistance. This is a safety hazard due to the possibility of electric shock.

Test motor low insulation resistance and high contamination

Individual Analysis - 3Phase


Company: Watersure Location: Test motor

EquipmentID: test position 3 Name: position 3 Type: 3PhaseAC

	32	21	13	
Resistance (Ω)	17.7	17.7	17.7	0.170
Impedance (Ω)	207	239	228	7.79
Inductance (mH)	329	380	362	7.84
Phase Angle (°)	71.9	70.8	70.7	0.727
I / F (%)	-42.2	-41.8	-41.9	0.236
Stator				
Rotor				
Insulation (MΩ)	8.14	MΩ	TVS	675
Contamination(%)	14.4%		Ref Value	
Capacitance (nF)	36.8	nF		
Frequency (Hz)	100		Reference	


Direct Test At Motor Manual Values

32




0% Sdev 0%

21



0% Sdev 0%

13





0% Sdev 0%

SAVE NOTE

TREND

Rotor

Findings


Degraded Insulation
Contaminated or Overheated

Recommend check at motor if tested from MCC.
Insulation Test Voltage: 500V


NOTE




Hydraulic pump motor earth fault with all-test pro 4.



Motor junction box full of watered down grease from NDE bearing.



After cleaning out reconnecting motor j/box readings still the same.



After removing rotor, discovered shorted winding to frame



CONTAMINATION (DISSIPATION FACTOR)

- Dissipation factor is used to indicate the capacitive property of the insulation materials used in the motor windings.
- When the insulation degrades over time, it becomes less resistive due to contamination or overheating and the DF will increase. Any value above 6 degrees indicates contamination or overheating.
- Along with the dissipation factor, capacitance is also measured which can help trend the insulation properties.
- As DF and capacitance are directly related to each other, when one of the tests returns an invalid result (e.g. out of range), then it means the other test results are not valid either.
- Measuring DF at too high or too low temps can introduce errors, and the IEEE recommends performing the tests close to 20 degree Celsius.
- DF testing is widely used on other electrical equipment such as power transformers, circuit breakers, generators and cables.

Example of low insulation resistance and high dissipation factor

Low insulation resistance combined high dissipation factor is a strong indicator of seriously degraded winding insulation.

Individual Analysis - 3Phase

Company: Watersure Location: Test motor
EquipmentID: test position 3 Name: position 3 Type: 3PhaseAC

	32	21	13	
Resistance (Ω)	OK 17.7	17.7	17.7	0.170
Impedance (Ω)	207	239	228	7.79
Inductance (mH)	329	380	362	7.84
Phase Angle ($^{\circ}$)	OK 71.9	70.8	70.7	0.727
I / F (%)	OK -42.2	-41.8	-41.9	0.236
Stator				
Rotor				
Insulation ($M\Omega$)	WARN 8.14			TVS 675
Contamination(%)	BAD 14.4%			Ref Value
Capacitance (nF)	36.8			nF
Frequency (Hz)	100			Reference

Direct Test At Motor Manual Values

Findings: Degraded Insulation, Contaminated or Overheated. Recommend check at motor if tested from MCC. Insulation Test Voltage: 500V

NOTE

SAVE NOTE, TREND, Rotor

32 21 13

0% Sdev 0% 0% Sdev 0% 0% Sdev 0%

CAPACITANCE, TVS AND RVS

CAPACITANCE:

The insulation between the winding conductors and the machines frame form a natural capacitor. Capacitance is a measure of a systems ability to store electrical charges. When the insulation system becomes coated in grease, oil, dust, or any other foreign matter, it will cause changes in capacitance. Closely linked to dissipation factor.

TEST VALUE STATIC (TVS):

This value is calculated from measurements made at several different frequencies through the motor stator windings. Any change in the winding insulation systems condition will be reflected in the TVS.


REFERENCE VALUE STATIC (RVS):

When a test record is saved as reference type in the instrument, the TVS is called the RVS. Each RVS is a baseline reading so other measured TVS can be trended over time for comparison for a specific machine.

DYNAMIC TESTING TO HIGHLIGHT STATOR AND ROTOR FAULTS.

- The dynamic tests measures in real time during manual rotation, a number of parameters in all three phases which together form the “test signature” for the rotor and stator.
- The test signature is then automatically analysed in the AT5 and give the user immediate results for Stator and Rotor issues.
- The 6 dotted lines each with 8 data points represent the rotor signature.
- The green lines are the stator signature.
- If the dotted lines do not have any significant variations, and the green lines are in a straight line, then there is good indication that the rotor and stator are both in good condition.


Dynamic tests can confirm stator issues and highlight rotor issues.



With a dynamic test, the rotor is manually rotated and a signature of both the rotor and stator are provided to highlight any faults with either rotor or stator

Dynamic test indicating both rotor and stator issues


	32	21	13	
Resistance (Ohm)				NA
Impedance (Ohm)				NA
Inductance (mH)				NA
Phase Angle (°)				NA
I / F (%)				NA
Stator	BAD			
Rotor	WARN			
Insulation (MOhm)		NA		TVS Ref Value
Contamination(%)		NA		Frequency
Capacitance (nF)		NA		
Findings:	<p>Stator winding issue found. Repeat the test to confirm it. Possible rotor issue. Repeat the test to confirm.</p> <p>Recommend check at motor if tested from MCC.</p>			
Notes:	Carried out same test multiple times with same results.			



Green lines do not line up indicating stator issue. Winding 13 dotted line crosses over stator line indicating rotor issues also.

Dynamic tests indicating both rotor and stator are good.

	32	21	13	
Resistance (Ohm)				NA
Impedance (Ohm)				NA
Inductance (mH)				NA
Phase Angle (°)				NA
I / F (%)				NA
Stator	OK			
Rotor	OK			
Insulation (MOhm)		NA		TVS Ref Value
Contamination(%)		NA		Frequency
Capacitance (nF)		NA		
Findings:	Good Stator Winding Good rotor Recommend check at motor if tested from MCC.			
Notes:				




Green lines and dotted lines balanced indicating good stator and rotor.

IMPORTANT THINGS TO BE AWARE OF WHEN USING ALL TEST PRO. 5:

- If motor is moving due to fan or pump being driven by air flow from wind, or bypassing valve causing pump to rotate backwards, then a voltage will be induced into windings. This will give incorrect readings. Any motor that has an indication of fault, ensure that it is not rotating.
- If tests carried out at MCC indicate a fault, repeat test at least 2 more times to check for repeatability. If imbalance still exists then retest at motor j/box.
- If motor still indicates winding short when tested at j/box do test 2 more times to check for repeatability. Then if possible, you will need to do dynamic test to confirm stator issues and any rotor issues.
- If resistance imbalance is significant, then all the other tests will be unreliable. Need to address the resistance issue before condemning the motor.
- Never condemn a motor without carrying out the steps above!
- Always disconnect outgoing cables from VSD drives to protect electronics inside VSD (if doing test from panel) or disconnect at motor j/box if doing test at motor.

Ensure only non acetic silicon is utilized on motor j/boxes!!



Dow corning 748 above is a non corrosive silicon suitable for motor j/boxes.

Typical silicon contains acetic acid and is very corrosive to motor connections!!